

# Gas sensor KSEC 717

for detection of Silane SiH4



#### **Features**

- The gas detector measures the selected gas concentration
- The gas detector is part of the digital KIMESSA CANline BUS-Network which is designed for up to 128 gas detectors and alarming units
- linearized and temperature-compensated digital CANline-BUS output signal
- 16...30 VDC supply voltage (4-wire cable)
- various gas sensor technologies available (electrochemical, Infrared, pellistor, semiconductor)
- factory calibration with calibration certificate to the specified measuring range
- Zero & Span potentiometers and calibration jack socket accessible from outside without opening the gas detector enclosure

- water- and dust-proof IP 65 enclosure
- rust-proof and acid-resitant steel enclosure
- Swiss-Made

www.kimessa.com KSEC 717 – 15/07/2016



#### **Gas sensor KSEC 717**

Gas: Silane
Gas formula: SiH4

Warranty: 12 month warranty
Position: 30 cm from Floor

## **Sensor specifications**

Measurement principle: Electrochemical
Measuring range: 0...50 ppm
Standard calibration: 0...20/50 ppm
Response time t 90: < 60 sec

Operating temperature:  $-20 \, ^{\circ}\text{C} \dots +45 \, ^{\circ}\text{C}$ Start up after approx. 1 hour

reconditioning:

Pressure range: atmospheric  $\pm 10\%$ 

Air humidity: 15...90% R.H. non-condensing


Position sensitivity: none

Long term output drift: < 2% signal loss/month

Life span at 20 °C: 2 years, depending on the

application

#### **Electronic and Dimensions**



### Housing

Housing protection: IP 65

Material: rust-proof and acid-resistant

Weight: 600 g

## **Specifications electronic**

Wiring digital: 4x 1,0 mm2, shielded

Supply: 16.5...30 VDC
Power consumption: max. 20 mA

Output signal digital: KIMESSA CANBUS

Switching output: no


## **Specifications construction**

Cable gland: 2x M16
Cable entry: bottom
Tests: CE
Display: no

Position: position independent

## **Inspection (Maintenance)**

The sensor and the electronic require an inspection. Routine calibration is recommended once or twice a year.



www.kimessa.com KSEC 717 - 15/07/2016