

# Gas sensor GSBM 983 (Ex)

for detection of Sulfur Trioxide SO3



# Features

- The gas detector measures the selected gas concentration
- The gas detector is part of the digital KIMESSA CANline BUS-Network which is designed for up to 128 gas detectors and alarming units
- linearized and temperature-compensated digital CANline-BUSoutput,
- 4-20mA or Modbus RTU with optional relays
- 16...30 VDC supply voltage (2-wire, 3-wire or 4-wire cable for CANline BUS-Network)
- digital MODBUS-RTU (RS 485) output signal
- various gas sensor technologies available (electrochemical, Infrared, pellistor, semiconductor)
- factory calibration with calibration certificate to the specified measuring range
- Calibration/ programming are easily carried out with the use of a hand held HAL magnetic sensor.
- water- and dust-proof IP 65 enclosure

- clearly arranged OLED-Display with concentration- and status information
- optional 3 potential free relay outputs (to control third party devices)
- optional relay contacts: various relay functions (manual/auto RESET, Energized/De-Energized)
- optional relay contacts: free programmable time delays and alarm levels
- optional 230 VAC supply for standalone operation
- The intrinsically safe design facilitates replacement of the electrochemical sensor without the need of a hot work permit.
- Option for ATEX-Class: II 2G Ex d ia IIC T4
- Swiss-Made



# Gas sensor GSBM 983 (Ex)

Gas: Gas formula: Alarm thresholds: Warranty: Position:

**Sensor specifications** 

Measurement principle:

Measuring range: Standard calibration:

Response time t 90:

Start up after

Operating temperature:

Sulfur Trioxide SO3 2 (pre-/ main-alarm) optional 12 month warranty 30 cm from Floor

Electrochemical

-5 °C ... +40 °C

approx. 1 hour

0...0,2 ppm

0...0,2 ppm

< 60 sec

# Housing

Housing protection: Material: Weight:

IP 65 Aluminum, RAL 5009 (stainless steel as an option) 1200 g

# **Specifications electronic**


| Wiring analogue:        | 3x 0,75 mm2, shielded            |
|-------------------------|----------------------------------|
| Wiring digital:         | 4x 1,0 mm2, shielded             |
| Supply:                 | 16.530 VDC                       |
| Power consumption:      | max. 200 mA                      |
| Output signal analogue: | 420 mA                           |
| Output signal digital:  | KIMESSA CANBUS / Modbus<br>RTU   |
| Switching output:       | 3 potential free (2A) (optional) |

#### **Specifications construction**

| Cable gland:            | 1x M25 (digital 2x M25)        |
|-------------------------|--------------------------------|
| Cable entry:            | left/right                     |
| Tests:                  | CE / II 2G Ex d ia IIC T4 Gb / |
|                         | BVS 15 ATEX E 065 X (opt.)     |
| Display:                | OLED-Display                   |
| Position:               | depending on display           |
| <b>RESET-Connector:</b> | no                             |

# **Inspection (Maintenance)**

The sensor and the electronic require at least an annual inspection. The electrolyte and membrane must be replaced once a year.



### **Electronic and Dimensions**

